



# SWEDISH TYPE APPROVAL 1138

## WITH DECISION ON PRODUCTION CONTROL

**KEYWORD:** Ventilation  
Flexible Ducts

**BBR 5, 6**

### Holder: Lindab Ventilation AB

Grevie, 269 82 BÅSTAD

Tel: +46 (0) 431-850 00

Fax: +46(0) 431-853 25

Email: [lindab@lindab.com](mailto:lindab@lindab.com)

Web: [www.lindab.com](http://www.lindab.com)

### Product name: Flexible Ventilation Duct KFH

Reinforced flexible uninsulated ventilation duct in polyester mesh with flame retardant PVC. Encapsulated in the PVC is a bronze coated spiral wire.

### Intended use

To be used as a connector between the cooker hood and the exhaust fan, in housing and in catering kitchens and ventilation duct in housing or within fire cells, with no flammable business

### Approval

Products made and installed according to related documents are approved with respect to the following sections of the Swedish Building Regulations (BBR):

Building products with assessed properties	1:4
Class designations: E*	5:231
Air treatment installations kitchen flues	5:526
Tightness class C**	6:255

\*According to EN 13501, ISO EN 11925-2

\*\* Positive. Max. pressure 5000 Pa, EN 13180-2001

For the intended use the products meet the following requirements of PBL, regulations governing the technical properties of materials, products etc. used in construction works Chapter 8 Section 4 about the technical characteristics of buildings and constructions.

2. Safety in case of fire
3. Protection with regard to hygiene, health and environment

Appendix 1: Associated documents	2018-01-12
Appendix 2: Product marking	2018-01-12
Appendix 3: Control	2018-01-12
Appendix 4: Basis for approval	2018-01-12

**Kiwa Sverige AB**  
Campus Gräsvik 1  
SE-371 75 Karlskrona

Tel +46 (0)455-30 56 00  
Fax +46 (0)455-104 36  
[bygg@kiwa.se](mailto:bygg@kiwa.se)  
[www.kiwa.se](http://www.kiwa.se)



Accred. no. 1913  
Certification of  
Products  
ISO/IEC 17065


Date of decision: 2018-01-12


Ref. no: 963/17

Valid until: 2023-01-11

Previous ref. no.: 282/15

**Kiwa Sverige AB**

  
Magnus Jerlmark  
Technical manager

  
Johnny Ostfeldt  
Project leader